

## M E M O R A N D U M

**DATE:** May 1, 2014

**TO:** Jill Thacher  
Planning & Development Services Unit

**FROM:** Patrick Cawley, P.E., Sr. Project Manager  
Public Services Area – Project Management

**RE:** Glendale Condominiums  
Project No. SP13-010

I have reviewed the site plan for the proposed development. I have the following comments:

1. A cul-de-sac or hammerhead ending should be installed on the east-west internal roadway to facilitate service vehicles, deliveries, and emergency vehicles.

PC:pc (C:\Documents and Settings\pcawley\My Documents\Site Plan Rvws\413 e huron.doc)

**C:** Cresson S. Slotten, P.E., Senior Project Manager  
Alison Heatley, Senior Project Engineer  
Leszek Sipowski, P.E., Senior Project Manager